

The device

SYSTEMAIR GENIOX AND GENIOX GO

a product of
Systemair AB
Industrivägen 3
SE 739 30 Skinnskatteberg
Sweden


conforms the hygiene requirements of the guideline
VDI 6022 sheet 1 (January 2018) Ventilation and
indoor-air quality; Hygiene requirements for ventilation
and air-conditioning systems and units.

The conformity inspection was passed by test units installed at the
Systemair group in Mülheim. Additionally Installation and User Instructions
have been checked. Audit period: April 2020 – June 2020.

The test parameters and results are available on the test report on the
test report 0119.002p2 of 06 July 2020. The test and the test certificate
are only valid for devices that were configured as hygienic versions with
the SystemairCAD design tool.

This certificate also attests the conformity to the hygiene requirements
of SWKI VA 104 (01/2019) at the time of inspection. The certificate is
valid for identical devices until June 2023, subject to any changes to the
design or materials used.

Essen, 06 July 2020


Hans Joachim Oldenburg
Site Manager

